

Environment Act Licence

Manitoba
Environment



Licence No. 1517

Issue Date NOVEMBER 26, 1991

In accordance with the Manitoba Environment Act (C.C.S.M. c. E125)

THIS LICENCE IS ISSUED TO:

RURAL MUNICIPALITY OF ROCKWOOD; APPLICANT **STONY MOUNTAIN WASTEWATER TREATMENT LAGOON**

The following limits, terms and conditions shall be complied with in connection with the operation of a wastewater collection system and the construction and operation of a wastewater treatment lagoon located in the southwest quarter of Section 2, Township 13, Range 2 EPM in the Rural Municipality of Rockwood and with discharge of treated effluent via the Penitentiary Drain and the Grassmere Drain to the Red River:

1. The Applicant shall direct all sewage generated within the unincorporated Village of Stony Mountain toward the wastewater treatment lagoon or other approved sewage treatment facilities.

2. The Applicant shall not discharge effluent from the wastewater treatment lagoon:
 - (a) where the organic content of the effluent, as indicated by the five day biochemical oxygen demand, is in excess of 30 milligrams per litre;

 - (b) where the fecal coliform content of the effluent, as indicated by the MPN index, is in excess of 200 per 100 millilitres of sample;

 - (c) where the total coliform content of the effluent, as indicated by the MPN index, is in excess of 1500 per 100 millilitres of sample;

- (d) between the first day of November of any year and the 15th day of May of the following year, unless prior approval, by the Director, is given;
 - (e) where a residual chlorine content is detectable in the effluent;
 - (f) when flooding from any cause is occurring along the effluent drainage route; or
 - (g) when such a discharge will cause or contribute to flooding in or along the effluent drainage route.
3. The Applicant shall operate and maintain the wastewater treatment lagoon in such a manner that:
- (a) the release of offensive odours is minimized;
 - (b) the organic loading on the primary cell of the lagoon system, as indicated by the five day biochemical oxygen demand, is not in excess of 56 kilograms per hectare per day; and
 - (c) the depth of sewage in the primary cells does not exceed 1.5 metres.
4. The Applicant shall, in case of physical or mechanical breakdown of the wastewater collection and/or treatment system:
- (a) notify the Director immediately;
 - (b) identify the repairs required to the wastewater collection and/or treatment system;
 - (c) complete the repairs in accordance with written instructions of the Director.

5. The Applicant shall, prior to the construction of the dikes for the wastewater treatment lagoon:
 - (a) remove all organic topsoil from the area where the dikes will be constructed; or,
 - (b) remove all organic material for a depth of 0.3 metres and a width of 3.0 metres from the area where the dike will be built, provided all the lagoon dikes are lined with clay or other suitable material as required by Clause 6, to a minimum thickness of one metre measured perpendicular to the face of the side wall.

6. The Applicant shall construct the wastewater treatment lagoon system with clay or other suitable material such that all interior surfaces of the lagoon structure are underlain with a minimum of 1 metre of soil having a hydraulic conductivity of 1×10^{-7} centimetres per second or less.

7. The Applicant shall arrange with the designated Environment Officer a mutually acceptable time and date for any required soil sampling between the 15th day of May and the 15th day of October of any year, unless prior approval, by the Director, is given.

8. The Applicant shall either:
 - (a) subject undisturbed soil samples from the completed wastewater treatment lagoon, to hydraulic conductivity tests, the number and location of samples to be specified by the designated Environment Officer up to a maximum of twenty samples; or
 - (b) where undisturbed soil samples cannot be taken, test the soil of 4 plane surfaces from the completed wastewater treatment lagoon, for hydraulic conductivity by an insitu field test method as prescribed by the designated Environment Officer.

9. The Applicant shall, not less than 2 weeks before the wastewater treatment lagoon is placed in operation, submit to the Director the results of the tests carried out pursuant to Clause 8.
10. The Applicant shall install and maintain a fence around the wastewater treatment lagoon to limit access.
11. The Applicant shall construct and maintain an all-weather access road to the wastewater treatment lagoon.
12. The Applicant shall provide the Director with "as-constructed" drawings of the wastewater treatment lagoon on or before July 1, 1992.



Larry Strachan, P. Eng.
Director
Environment Act

FILE : 3367.00