

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION  
 UNDER THE CLEAN ENVIRONMENT ACT

---

Re: The Clean Environment Commission and the Frontier School Division and the Department of Public Works of the Province of Manitoba, applicants,

- WHEREAS pursuant to the provisions of The Clean Environment Act, M. M. Dillon Limited, consulting engineers, has submitted an application on behalf of the Frontier School Division and the Department of Public Works of Manitoba to the Clean Environment Commission in connection with the operation of a sewage lagoon system serving the Waterhen School and teacherage, said lagoon system being located on part of the SE $\frac{1}{4}$  17-33-15 WPM in the Local Government District of Alonsa, Manitoba with effluent drainage via highway ditch (PTH 328) and natural drainage towards Lake Manitoba,
- AND WHEREAS no representation was made to the Commission by any person who is or is likely to be affected by an Order of the Commission prescribing limits in connection with the said operation,
- AND WHEREAS the Clean Environment Commission considered the application on the 27th day of May, 1974,

IT IS HEREBY ORDERED THAT

1. The applicants shall ensure that all facilities for the treatment of sewage and holding of effluent are constructed of impervious material and said facilities are maintained and operated in such a manner as to prevent the contamination of groundwater,
2. The applicants shall ensure that the said sewage lagoon is operated in such a manner as to minimize the release of offensive odours,
3. The applicants shall ensure that the biochemical oxygen demand loading on the primary cell of the said sewage lagoon does not exceed 50 pounds per acre per day,
4. The applicants shall ensure that:
  - (a) the biochemical oxygen demand of the effluent of the said sewage lagoon does not exceed 30 milligrams per litre,
  - (b) the total coliform MPN index of the effluent of the said sewage lagoon does not exceed 1500 per 100 millilitres of sample,

*Assigned to  
 Eng. Apps.  
 June 12/74  
 a.b.m./m.j.*

. . continued

- 2 -

Department of Public Works  
and Frontier School Division

5. The applicants shall ensure that no discharge of effluent takes place between the first day of November in any one year and the fifteenth day of May in the following year.

Order No. 356

Dated at the City of Winnipeg  
this 31st day of May 1974



Chairman,  
Clean Environment Commission

C-b-810