ORDER COPY

410 84

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION

UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and MR. PAUL MARSHALL, Applicant,

WHEREAS

pursuant to the provisions of The Clean Environment Act, Mr. Paul Marshall submitted an application to The Clean Environment Commission to prescribe limits in connection with the operation of an existing sewage lagoon system, located in the NE% of Section 15-55-26 WPM in the Local Government District of Consol, Manitoba, serving an operation known as Valley View Trailer Park, with discharge of effluent to the Pasquia River,

AND WHEREAS

no representation was made to the said Commission by any person who is, or is likely to be, affected by an Order of the Commission prescribing limits in connection with the said operation,

AND WHEREAS

the said Commission considered the application on the 9th day of October, 1973,

IT IS HEREBY ORDERED THAT

- The Applicant shall ensure that all the facilities for the treatment of sewage and the holding of effluent are maintained and operated in such a manner as to prevent the contamination of groundwater,
- The Applicant shall ensure that said sewage lagoon system is operated in such a manner as to minimize the release of offensive odours,
- 3. The Applicant shall ensure that the biochemical oxygen demand loading on the primary cell of the said lagoon system does not exceed 50 pounds per acre, per day,
- 4. The Applicant shall ensure that the quality of the final effluent from said sewage lagoon system is such that:

C-b-253.1

assigned to borted 4.

- 4. cont'd . . .
 - (1) the biochemical oxygen demand does not exceed 30 milligrams per litre and,
 - (2) the total coliform MPN index does not exceed 1500 per 100 millilitres of sample,
- 5. The Applicant shall ensure that no discharge of effluent from the said holding pond takes place between the first day of November in any year and the fifteenth day of May in the following year.