## AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION

INDER	THE	CLEAN	ENVIRONMENT	ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and the MANITOBA WATER SERVICES BOARD, Applicant,

WHEREAS

pursuant to the provisions of The Clean Environment Act, M.M. Dillon Limited submitted an application, on behalf of the Manitoba Water Services Board, to The Clean Environment Commission to prescribe limits in connection with the operation of a sewage lagoon system, located in the SW4 of Section 32-64-26 WPM in the Local Government District of Consol, Manitoba serving the unincorporated village of Cranberry Portage, the said sewage lagoon system to include the use of Gold Hill Lake as the secondary lagoon, with discharge of effluent into First Cranberry Lake,

AND WHEREAS

no representation was made to the said Commission by any person who is, or is likely to be, affected by an order of the Commission prescribing limits in connection with the said operation,

AND WHEREAS

the said Commission considered the application on the 25th day of November, 1974,

IT IS HEREBY ORDERED THAT

1 e

at a al ge e riar e e i 5 unc e a

Ossignal to Brother Brother CEO/BH

C-6-872

Manitoba Water Services Board (umincorporated village of Cranberry Portage)

- 2 -

- 4. Cont'd . . .
  - (a) between the first day of November in any year and the fifteenth day of May of the following year; and
  - (b) between the fifteenth day of June in any year and the fifteenth day of September of the same year;
- 5. The Applicant shall ensure that the quality of the effluent of the said sewage lagoon system, before discharge from the secondary cell known as Gold Hill Lake, is such that:
  - (a) the biological oxygen demand (B.O.D.) does not exceed 30 milligrams per litre; and
  - (b) the total coliform content, as indicated by the MPN index, does not exceed 1500 per 100 millilitres of sample.

Clean Environment Commission

Order No. 422			
Dated at the City of Winnipeg			
this 31 day of DECEMBER	, 1974.	Chairman	El Mes