



Sustainable Development

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg Manitoba R3C 1A5
T 204 945-8321 F 204-945-5229
www.gov.mb.ca/sd/eal

Client File No. 1069.10

September 12, 2017

Mr. Chris Carroll, P.Eng., MBA
Manager of Wastewater Services Division
City of Winnipeg
110-1199 Pacific Avenue
Winnipeg, MB R3E 3S8

Dear Mr. Carroll:

Re: Notice of Alteration - City of Winnipeg South End Water Pollution Control Centre (SEWPCC) - Environment Act Licence No. 2716 RR

Your letter dated October 20, 2016 along with supporting documentation is hereby acknowledged as a Notice of Alteration in accordance with Section 14 of The Environment Act. In your letter you requested an extension to the date the more stringent effluent criteria apply; that is, the deadline for completion of construction of the upgraded and expanded facility.

Per my letter to you dated November 5, 2015, the construction deadline was extended to December 31, 2016 on the condition that a detailed alternative analysis report be filed with me and that the Clean Environment Commission provide input on the draft report prior to its submission. The analysis report has been received and reviewed. You are now requesting an extension of the completion date to March 31, 2021 or September 30, 2021 with achievement of chemical phosphorus removal by February 15, 2020.

Your request is an alteration to Clause 14b of Environment Act Licence No. 2716 RR, with subsequent alterations to Clauses 22, 27, 28 and 29. Based on the review of submitted documents, the alteration is approved in accordance with Section 14(2) of The Environment Act subject to the following conditions:

1. The City of Winnipeg shall continue to submit to the Director progress reports every six months on the planning, design, construction and commissioning of the SEWPCC.
2. The construction of the upgraded wastewater treatment plant shall be completed before February 29, 2020 such that the phosphorus limit of 1.0 mg/L will be met.
3. The construction and commissioning of the upgraded wastewater treatment plant shall be completed before December 31, 2021 such that the effluent limits specified in Clause 28 will be met.

Please be advised that this approval is contingent on the acceptance of a revised Environment Act Licence to be issued in the near future.

Sincerely,



Tracey Braun, M.Sc.
Director

c: Don Labossiere/Donna Smiley/Yvonne Hawryliuk, Environmental Compliance and
Enforcement Branch
Public Registries