

File No.: 3367.10

June 18, 2024

Chris Luellman
Chief Administrative Officer
Rural Municipality of Rockwood
285 Main Street
P. O. Box 902
Stonewall MB R0C 2Z0
info@rockwood.ca

Dear Chris Luellman:

**Re: Rural Municipality of Rockwood - Wastewater Treatment Facility
Environment Act Licence No. 3133 - Notice of Alteration Approval**

Thank you for your notice of alteration dated May 21, 2024. The department understands you wish to install a new forcemain into the primary cell and two new lift stations for the Rural Municipality of Rockwood Wastewater Treatment Facility.

I approve the alteration per section 14(2) of The Environment Act with the following conditions:

- The licensee shall take measures to prevent accidental releases of untreated sewage into the environment while connecting the forcemain to the existing wastewater treatment lagoon.
- The licensee shall properly seal any remaining holes on the reworked clay liner with bentonite slurry after the pipe installation.
- Clause 48 of the Environment Act Licence No. 3133 regarding contents of the annual report is updated with the following sub-clauses:
 - i) a summary of any wastewater collection system overflows; and
 - j) expansions to any collection system with associated capacity assessment.
- Prepare record drawings for the proposed construction work and label the drawings "Record Drawings"; and provide to the director an electronic copy of the "record drawings" within four months after commissioning.

- Please notify the assigned Environment Officer of Environmental Compliance and Enforcement Branch per clause 7 of Environment Act Licence No. 3133.
- All licence requirements and federal, provincial, and municipal regulations and by-laws must be followed. The licensee must get approval from the director per The Environment Act to alter the development.

All clauses of Environment Act Licence No. 3133 remain in effect. This approval is available on the public registry at https://www.gov.mb.ca/sd/eal/registries/3367.1_rockwoodstnymtn/index.html

If you have any questions regarding this approval, please contact, Barsha Sagan, A/Senior Environmental Engineer, Environmental Approvals Branch at Barsha.Sagan@gov.mb.ca or 204-795-7175.

For questions relating to the ongoing administration of the licence, please contact Tyler Kneeshaw, Regional Supervisor, Environmental Compliance and Enforcement Branch at EnvCEInterlake@gov.mb.ca or 204-239-3608.

Sincerely,

Original Signed By
Agnes Wittmann
Director
The Environment Act

c. Barsha Sagan
Tyler Kneeshaw