

Environmental Approvals Branch



Attn: Tracey Braun

Regarding the inspection that was done on Springhill Colony's wastewater lagoon, we would like to apply for a minor alteration. The officer (Kayla Hagenson) that was here to do the inspection noted that the east bank on the secondary cell was showing some signs of erosion. What we would like to do is line the bank with stone or riprap to take care of that problem. So as soon as we would have your approval we would go ahead and fix that. If you have any further questions you can call me at 204-841-3726.

Rodney Wollmann

Springhill Colony

Box 849

Neepawa, MB

R0J-1H0