



Conservation and Water Stewardship

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg, Manitoba R3C 1A5
T 204 945-8321 F 204 945-5229
www.gov.mb.ca/conservation/eal

File: 5704.00

December 17, 2014

Mr. Jonathan Waldner
Oakland Colony
Box 18
Carroll MB R0K 0K0
geraldw78@gmail.com

Dear Mr. Waldner:

**Re: Oakland Colony Wastewater Treatment Lagoon
Environment Act Licence No. 3113**

This is in response to a letter of September 16, 2014 from Daniel Burns of Burns Maendel Consulting Engineers Ltd. to Bruce Webb of this office concerning an alteration in the size of the above noted wastewater treatment lagoon. The letter explains that the constructed dimensions of the secondary cell of the facility are 106.0 m by 34.8 m, for a total useable hydraulic storage capacity in both cells of 7,209 m³. This results in a daily capacity of 31.3 m³/day, sufficient to service a population of 114 people.

We are satisfied that the environmental effects of this alteration in the size of the facility are insignificant in view of the long time period anticipated before the colony reaches this size. As a result, the alteration is hereby approved pursuant to Section 14(2) of *The Environment Act*.

If you have questions on this matter, please contact Bruce Webb at bruce.webb@gov.mb.ca or (204) 945-7021.

Yours truly,

“original signed by”
Tracey Braun, M.Sc.
Director

c: Public Registries
Daniel Burns, P. Eng., Burns Maendel Consulting Engineers Ltd.
Don Labossiere, Environmental Compliance and Enforcement Branch
Tim Prawdzik, Environmental Compliance and Enforcement Branch
Peter Crocker, Environmental Compliance and Enforcement Branch